

Certificate

This is to certify that **Firebox Australia Pty Ltd**

ABN 75 116 370 793

Head Office Address Lot 5 / 19 Balook Drive
Beresfield, New South Wales, 2322
Australia

Holds Certificate Number **BMP 520106 (ID3119)**

Is authorised to use the BSI registered Benchmark Product Certification Trademark, on products identified in the Product Certification Schedule that is attached to this Product Certification Certificate. Such products have been Type Tested and are manufactured under the Product Certification Requirements monitored by BSI to ensure that the manufacturing process has the capability to consistently produce products in compliance with and are Certified to:

AS/NZS 1841.5:2007 - Portable fire extinguishers - Specific requirements for powder type extinguishers

For and on behalf of BSI

Marc Barnes, Managing Director, BSI Group ANZ Pty Ltd

Originally registered
23/03/2006

Latest issue
25/01/2016

Expiry date
22/01/2021



...making excellence a habit.

Schedule

This schedule supports the Product Certification Certificate for **Firebox Australia Pty Ltd**

ABN/Local Business Number **75 116 370 793**

Head Office Address **Lot 5 / 19 Balook Drive
Beresfield, New South Wales, 2322
Australia**

Holds Certificate Number **BMP 520106 (ID3119)**

Standard **AS/NZS 1841.5:2007 - Portable fire extinguishers - Specific requirements for powder type extinguishers**

Issue date **22/01/2016**

Model	BSI Review date	Description
FB25ABE	15/11/2011	2.5kg – 3A:40B:E – Fire Rating ABE Dry Powder Fire Extinguisher
FB45ABE	15/11/2011	4.5kg – 4A:60B:E – Fire Rating ABE Dry Powder Fire Extinguisher
FB075ABE	01/04/2011	0.75kg – 1A:10B:E – Fire Rating ABE Dry Powder Fire Extinguisher
FB10ABE	01/04/2011	1kg – 1A:20B:E – Fire Rating ABE Dry Powder Fire Extinguisher
FB15ABE	01/04/2011	1.5kg – 2A:30B:E – Fire Rating ABE Dry Powder Fire Extinguisher
FB20ABE	01/04/2011	2kg – 2A:30B:E – Fire Rating ABE Dry Powder Fire Extinguisher
FB90ABE	01/04/2011	9kg – 6A:80B:E - Fire Rating ABE Dry Powder Fire Extinguisher
FB45ABEHP	10/06/2015	4.5kg – 4A:80B:E - Fire Rating ABE Dry Powder Fire Extinguisher

BMP 520106
22/01/2016 Page 2 of 2



...making excellence a habit.