

ENEC Certificate

This is to certify that:

D W Windsor Ltd
Pindar Road
Hoddesdon
EN11 0DX
United Kingdom

Holds Certificate Number:

ENEC 638745

In respect of:

EN 60598
General requirements for Luminaire product safety

(hereinafter called the certificate holder), having been assessed against the requirements of the CENELEC Agreement on the use of a commonly agreed Mark of Conformity for products complying with European standards (in short the ENEC Agreement), the right and Licence to use the commonly agreed Mark of Conformity for products shown below in respect of the goods particularly described in the Appendix bearing the same number as the certificate.

Goods shall be produced by the certificate holder only at the address given above in accordance with the relevant European Standard as detailed above. The Certificate is granted subject to the Specific Rules for the ENEC Agreement and the BSI Administration scheme.



For and on behalf of BSI:

Gary Fenton, Global Product Certification Director

First Issued: 2016-02-15

Latest Issue: 2017-06-06



EUROPEAN
NORMS
ELECTRICAL
CERTIFICATION

Page: 1 of 2

...making excellence a habit.™

ENEC Certificate

No. ENEC 638745

EN 60598-2-3:2003 + A1:2011 used in conjunction with EN 60598-1:2015.

Kirium Series Street Luminaires.

BSI reference report No. TR/15/140 (8407454) dated 8 February 2016.

Class I, IP66.

Model	Lamp type	Voltage	Ta	Dimensions (mm)
Kirium 1	15 LEDs	220-240 V 50 Hz	25 °C	706 x 167 x 343
Kirium 2	30 LEDs	220-240 V 50 Hz	25 °C	706 x 167 x 343
Kirium 3	45 LEDs	220-240 V 50 Hz	25 °C	706 x 167 x 343
Kirium Mini	5 / 10 / 15 LEDs	220-240 V 50 Hz	50 °C	585 x 98 x 155

Kirium PRO Series Street Luminaires.

BSI reference report No. 8666237 dated 6 June 2017.

Class I, IP66.

Model	Lamp type	Voltage	Ta	Dimensions (mm)
Kirium PRO 1	8 / 16 / 24 / 32 LEDs	240 V 50 Hz	25 °C	610 x 140 x 350
Kirium PRO 2	32 / 48 / 64 LEDs	240 V 50 Hz	25 °C	720 x 140 x 350
Kirium PRO 3	64 / 80 / 96 / 128 LEDs	240 V 50 Hz	25 °C	1010 x 167 x 415
Kirium PRO MIDI	24 LEDs	240 V 50 Hz	25 °C	451 x 119 x 227
Kirium PRO MINI	4 / 8 / 16 LEDs	240 V 50 Hz	25 °C	400 x 119 x 227

First Issued: 2016-02-15

Latest Issue: 2017-06-06

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.