

Kitemark™ Certificate

This is to certify that:

DSPA BV
Hogelandseweg 30
Nijmegen
6545 AC
The Netherlands

Holds Certificate Number:

KM 632907

In respect of:

BRL-K23001/04
Aerosol Generating Fire Extinguishing System Units

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2015-06-30

Latest Issue: 2024-07-17

Effective Date: 2024-07-17

Expiry Date: 2026-01-17



Page: 1 of 6

Kitemark™ Certificate

No. KM 632907

Model No	Description	Branded
DSPA 8-1	Construction: Cylindrical, axial Efficiency: 100 % Discharge: 67 – 89 seconds Distribution: Minimum height (2.44m) 9.76 x 3.66m Maximum height (4.88m) 4.88 x 3.66 m Activation: Electrical	DSPA
DSPA 8-1-60	Construction: Cylindrical, axial Efficiency: 100 % Discharge: 48 – 58 seconds Distribution: Minimum height (2.44m) 9.76 x 3.66m Maximum height (4.88m) 4.88 x 3.66 m Activation: Electrical	DSPA
DSPA 11-1	Construction: Disk, radial, double shaped plate Efficiency: 100 % Discharge: 6 – 10 seconds Distribution: Minimum height (0.50m) 3.66 x 1.22m Maximum height (1.83m) 1.22 x 1.22 m Activation: Electrical	DSPA

All the above products are certified to BRL-K23001/04

First Issued: 2015-06-30
Latest Issue: 2024-07-17

Effective Date: 2024-07-17
Expiry Date: 2026-01-17

Kitemark™ Certificate

No. KM 632907

Model No	Description	Branded
DSPA 11-2	Construction: Disk, radial, double shaped plate Efficiency: 88 – 100% Discharge: 9 – 15 seconds Distribution: Minimum height (0.50m) 3.66 x 2.44m Maximum height (2.44m) 1.22 x 1.22m Activation: Electrical	DSPA
DSPA 11-3	Construction: Disk, radial, double shaped plate Efficiency: 90 – 100% Discharge: 14 – 26 seconds Distribution: Minimum height (0.50m) 3.66 x 2.44m Maximum height (2.44m) 1.22 x 1.22m Activation: Electrical	DSPA
DSPA 11-4	Construction: Disk, radial, double shaped plate Efficiency: 100 % Discharge: 19 – 31 seconds Distribution: Minimum height (1.22m) 3.66 x 3.66m Maximum height (3.05m) 1.83 x 1.83 m Activation: Electrical	DSPA

All the above products are certified to BRL-K23001/04

First Issued: 2015-06-30
Latest Issue: 2024-07-17

Effective Date: 2024-07-17
Expiry Date: 2026-01-17

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 632907

Model No	Description		Branded
DSPA 11-5	Construction:	Disk, radial, double shaped plate	DSPA
	Efficiency:	94 – 100%	
	Discharge:	40 – 60 seconds	
	Distribution:	Minimum height (1.22m) 4.88 x 3.66m Maximum height (3.66m) 2.44 x 2.44m	
	Activation:	Electrical	
DSPA 11-6	Construction:	Disk, radial, double shaped plate	DSPA
	Efficiency:	100 %	
	Discharge:	30 – 50 seconds	
	Distribution:	Minimum height (1.22m) 7.32 x 3.66 m. Maximum height (3.66m) 2.44 x 2.44 m	
	Activation:	Electrical	
DSPA 11-7	Construction:	Disk, radial, double shaped plate	DSPA
	Efficiency:	100 %	
	Discharge:	30 – 50 seconds	
	Distribution:	Minimum height (1.22m) 7.32 x 1.22m. Maximum height (3.05m) 1.83 x 1.83 m	
	Activation:	Electrical	

All the above products are certified to BRL-K23001/04

First Issued: 2015-06-30

Latest Issue: 2024-07-17

Effective Date: 2024-07-17

Expiry Date: 2026-01-17

Page: 4 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 632907

Model No	Description	Branded
DSPA 12-1	Construction: Disk, radial, single shaped plate Efficiency: 100% Discharge: 9 – 11 seconds Distribution: Minimum height (0.50m) 0.81 x 0.73 m Maximum height – NA Activation: Electrical or thermal cord	DSPA
DSPA 12-2	Construction: Disk, radial, single shaped plate Efficiency: 100% Discharge: 13 – 15 seconds Distribution: Minimum height (0.50m) 0.81 x 1.6 m. Maximum height (0.8m) 0.81 x 0.74 Activation: Electrical or thermal cord	DSPA
DSPA 12-3	Construction: Disk, radial, single shaped plate Efficiency: 96 - 100% Discharge: 9 – 11 seconds Distribution: Minimum height (0.80m) 0.81 x 1.49m Maximum height (1.99m) 0.81 x 0.86m Activation: Electrical or thermal cord	DSPA

All the above products are certified to BRL-K23001/04

First Issued: 2015-06-30
Latest Issue: 2024-07-17

Effective Date: 2024-07-17
Expiry Date: 2026-01-17

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 632907

Model No	Description	Branded
DSPA 12-4	Construction: Disk, radial, single shaped plate Efficiency: 100% Discharge: 11 – 14 seconds Distribution: Minimum height (1.60m) 0.81 x 1.99 m Maximum height (1.99m) 0.81 x 1.60 m Activation: Electrical or thermal cord	DSPA
DSPA 12-5	Construction: Disk, radial, single shaped plate Efficiency: 90 - 100% Discharge: 5 – 7 seconds Distribution: Minimum height (0.50m) 0.81 x 0.73m Maximum height (0.53m) 0.25 x 0.59m Activation: Thermal cord	DSPA

All the above products are certified to BRL-K23001/04

First Issued: 2015-06-30
Latest Issue: 2024-07-17

Effective Date: 2024-07-17
Expiry Date: 2026-01-17

Page: 6 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.