

Kitemark™ Certificate

This is to certify that:

International Gulf Trading Company
Bldg. 272, Area 81, St. 9, New SME
New Industrial Area
PO Box 6572
Doha
Qatar

Holds Certificate Number:

KM 671502

In respect of:

BS EN 1866-1:2007
Mobile Fire Extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2019-08-28

Latest Issue: 2025-04-29

Effective Date: 2025-04-29

Expiry Date: 2026-05-31

Page: 1 of 2



Kitemark™ Certificate

No. KM 671502

Model No	Description	GA Drawing Reference, Revision & Date	Type Test Report & Pressure Safety or Technical File Review
P25	25 kg ABC powder (CF MAP 50 RM0175 - 50% MAP), stored pressure. Temperature range: -30 °C to +60 °C Working pressure: 15 bar Fire ratings: A & IVB	CF/SP-25-C50/GA/03, revision 03 dated 23/10/2017	Technical file review 3717937
P50	50 kg ABC powder (CF MAP 50 RM0175 - 50% MAP), stored pressure. Temperature range: -30 °C to +60 °C Working pressure: 15 bar Fire ratings: A & IVB	CF/SP-50-C50/GA/03, revision 03 dated 23/10/2017	Technical file review 3717937
P100	100 kg ABC powder (CF MAP 50 RM0175 - 50% MAP), stored pressure. Temperature range: -30 °C to +60 °C Working pressure: 15 bar Fire ratings: A & IVB	CF/SP-100-C50/GA/03, revision 03 dated 23/10/2017	Technical file review 3717937
F50	50 litre foam (water + 6% KV LITE 3%-C6), stored pressure. Temperature range: 5 °C to +60 °C Working pressure: 15 bar Fire ratings: A & IVB Not for use on live electrical equipment	CF/SP-F50-MS/GA/02, revision 02 dated 23/10/2017	Technical file review 3717937
F100	100 litre foam (water + 6% KV LITE 3%-C6), stored pressure. Temperature range: 5 °C to +60 °C Working pressure: 15 bar Fire ratings: A & IVB Not for use on live electrical equipment	CF/SP-F100-C50/GA/02, revision 02 dated 23/10/2017	Technical file review 3717937
C10	10 kg carbon dioxide, steel cylinder. Temperature range: -20 °C to +60 °C Working pressure: 174 bar Fire rating: 70B	OLT-MTZ10-00, revision A0 dated 15.08.20	BSI report 8715259 (1 of 1) Model: MTZ10 – 10 kg CO ₂ dated 19 October 2018. PED, CE 671503 and CE 671504 (2797).

All the above products are branded as Oryx Fire and certified to BS EN 1866-1:2007

First Issued: 2019-08-28

Latest Issue: 2025-04-29

Effective Date: 2025-04-29

Expiry Date: 2026-05-31

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.