

Kitemark™ Certificate

This is to certify that:

Xuancheng Jindun Fire
Fighting Equipment Co.,Ltd
Shizi Town,
Langxi County,
Anhui
242131
China

Holds Certificate Number:

KM 707274

In respect of:

BS EN 3
Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2022-05-25

Latest Issue: 2025-04-10

Effective Date: 2025-05-25

Expiry Date: 2028-05-24

Page: 1 of 3



Kitemark™ Certificate

No. KM 707274

Model No	Description	GA Drawing Reference, Revision & Date	Technical File Review
JD-MFZ1-00	1 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire rating: 8A & 34B	JD-MFZ1-00 Revision 03 Date 2021.10.18	3886086
JD-MFZ2-00	2 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire rating: 13A & 55B	JD-MFZ2-00 Revision 02 Dated 2018-09-05	3643458
JD-MFZ4-00	4 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire rating: 21A & 113B	JD-MFZ4-00 Revision 03 Date 2021.10.18	3886086
JD-MFZ6-00	6 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire rating: 34A & 183B	JD-MFZ6-00 Revision 02 Dated 2018-09-05	3643458
JD-MFZ9-00	9 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire rating: 43A & 233B	JD-MFZ9-00 Revision 02 Dated 2018-09-05	3643458
JD-MFZ12-00	12 kg, ABC 40% powder powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire rating: 55A & 233B	JD-MFZ12-00 Revision 03 Date 2021.10.18	3886086
JD-FX2-00	2 litre, water+additive, stored pressure. Temperature range: -15°C to +60 °C Working pressure: 12 bar Fire rating: 13A 34B 25F	JD-FX2-00 Revision 02 Date 2021.12.08	3394427
JD-FX6-00	6 litre, water+additive, stored pressure. Temperature range: -15°C to +60 °C Working pressure: 12 bar Fire rating: 34A 113B 75F	JD-FX6-00 Revision 02 Date 2020.12.08	3394427

First Issued: 2022-05-25

Latest Issue: 2025-04-10

Effective Date: 2025-05-25

Expiry Date: 2028-05-24

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 707274

Model No	Description	GA Drawing Reference, Revision & Date	Technical File Review
JD-FX9-00	9 litre, water+additive, stored pressure. Temperature range: -15°C to +60 °C Working pressure: 12 bar Fire rating: 55A 183B 75F	JD-FX9-00 Revision 02 Date 2020.12.08	3394427
JD-MPZ2-00	2 litre, 3% AFFF foam, stored pressure. Temperature range: +5°C to +60 °C Working pressure: 12 bar Fire rating: 5A & 34B	JD-MPZ2-00 Revision 02 Date 2020.12.08	9722110
JD-MPZ6-00	6 litre, 3% AFFF foam, stored pressure. Temperature range: +5°C to +60 °C Working pressure: 12 bar Fire rating: 13A	JD-MPZ6-00 Revision 02 Date 2020.12.08	9722110
JD-MPZ9-00	9 litre, 3% AFFF foam, stored pressure. Temperature range: +5°C to +60 °C Working pressure: 12 bar Fire rating: 21A	JD-MPZ9-00 Revision 02 Date 2020.12.08	9722110
JD-MT2A-00	2 kg, carbon dioxide. Temperature range: -30°C to +60 °C Fire rating: 34B	JD-MT2A-00 Revision 05 Date 2022.06.29	5091783
JD-MT5A-00	5 kg, carbon dioxide. Temperature range: -20°C to +60 °C Fire rating: 89B	JD-MT5A-00 Revision 05 Date 2022.06.29	5091783
JD-FX2A-00	2 litre, water+additive, stored pressure. Temperature range: -15°C to +60 °C Working pressure: 12 bar Fire rating: 13A 34B 25F	JD-FX2A-00 Revision 02 Date 2021.12.08	30072118
JD-FX6A-00	6 litre, water+additive, stored pressure. Temperature range: -15°C to +60 °C Working pressure: 12 bar Fire rating: 34A 113B 75F	JD-FX6A-00 Revision 02 Date 2020.12.08	30072118
JD-FX9A-00	9 litre, water+additive, stored pressure. Temperature range: -15°C to +60 °C Working pressure: 12 bar Fire rating: 55A 183B 75F	JD-FX9A-00 Revision 02 Date 2020.12.08	30072118

All the above products are certified to BS EN 3-7:2004+A1:2007

Suitability for li-ion fire types is outside the scope of this certification

First Issued: 2022-05-25

Effective Date: 2025-05-25

Latest Issue: 2025-04-10

Expiry Date: 2028-05-24

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).