

Kitemark™ Certificate

This is to certify that:

Auto FireX LLP
Gram Dungsil, Malla Patti Pandey Gaon,
Bhimtal(Nainital)
Uttarakhand
263136
India

Holds Certificate Number:

KM 786033

In respect of:

BS EN 17446:2021
Fire Extinguishing Systems in Commercial kitchens

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2023-06-12

Latest Issue: 2023-06-12

Effective Date: 2023-06-12

Expiry Date: 2026-06-11



Page: 1 of 2

Kitemark™ Certificate

No. KM 786033

Description	Model No	Additional Info	Branded As
Mechanical Kitchen Fire Suppression System tested to BS EN 17446:2021. 8 Flow Capacity, 10 Litre Flame Killer Wet Chemical, Stored Pressure, Temperature Activated (Thermo Bulb) or Manual Activated.	HS-8	Suitable for use on Deep Fat Fryers, Griddles, Range Tops & Wok's	AFX M
Mechanical Kitchen Fire Suppression System tested to BS EN 17446:2021. 16 Flow Capacity, 20 Litre Flame Killer Wet Chemical, Stored Pressure, Temperature Activated (Thermo Bulb) or Manual Activated.	HS-16	Suitable for use on Deep Fat Fryers, Griddles, Range Tops & Wok's	AFX M
Pneumatic Kitchen Fire Suppression System tested to BS EN 17446:2021. 8 Flow Capacity, 10 Litre Flame Killer Wet Chemical, Stored Pressure, Temperature Activated (Thermoplastic Tubing) or Manual Activated.	HSP-8	Suitable for use on Deep Fat Fryers, Griddles, Range Tops & Wok's	AFX P
Pneumatic Kitchen Fire Suppression System tested to BS EN 17446:2021. 16 Flow Capacity, 20 Litre Flame Killer Wet Chemical, Stored Pressure, Temperature Activated (Thermoplastic Tubing) or Manual Activated.	HSP-16	Suitable for use on Deep Fat Fryers, Griddles, Range Tops & Wok's	AFX P

First Issued: 2023-06-12

Latest Issue: 2023-06-12

Effective Date: 2023-06-12

Expiry Date: 2026-06-11

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.